






Class 2 0-10VDC Dimming

SEQUENCE OF OPERATION

1. General lighting (a, adz1) auto On to 50% when occupancy detected.
2. Manual On/Off/Dim and reduction control of general lighting (a, adz1) with dimmer switches.
3. Lighting in daylight zone (adz1) will continuously dim based on daylight contribution to maintain at least 35FC at task level.
4. Auto Off all lighting within 20 minutes of occupants leaving.
5. Emergency lighting fixtures will transfer to emergency power source and full On with loss of normal power.

TYPICAL DRAWING DETAIL NOTES

1. Follow manufacturer instructions for proper product placement, installation, wiring and operation.
2. Diagram is typical for space type. Provide proper quantity and type of occupancy sensors, switches, room controllers, daylighting sensors, etc., per code requirement for each space.
3. Use pre-terminated CAT5e cables with splitters and couplers as needed using a free topology wiring arrangement to connect lighting control devices.
4. Use LM-MSTP wire to daisy change connect network bridge devices in each room. Twist together and tape back the shielded wire and DO NOT connect to network terminals.



Wattstopper			
<small>www.legrand.us/wattstopper Phone: 888-852-2278</small>			
legrand®			
Title IECC 2015 OPEN OFFICE 0-10V DIMMING			
Scale None	Drawing# I1500DD-W	Date 10/3/2017	Rev.